

## VIDYALANKARE EDUCATIONAL CAMPUS 2021-2022

### OVERHEAD WATER TANKS CLEANING REPORT DATEWISE

TANK NO	BLDG/ BLOK	WATER TYPE	CAP	2021				2022			
				FEB	JUN	OCT	DEC	FEB	JUN	OCT	DEC
1.	VIT -A	WELL	3000 L		30		02		12		20
2.	VIT -A	WELL	5000 L		30		02		12		20
3.	VIT -A	DRINKING	6000 L	27	1	4		26	12	24	
4.	VIT -B	WELL	3000 L		1		02		12		20
5.	VIT -B	WELL	5000 L		1		02		12		20
6.	VIT -B	DRINKING	6000 L	27	1	4		26	12	24	
7.	VIT -C	WELL	3000 L		1		02		12		20
8.	VIT -C	WELL	5000 L		2		02		12		20
9.	VIT -C	DRINKING	6000 L	27	2	4		26	12		
10.	VIT -D	WELL	3000 L	DC	DC	DC	DC	DC	DC	DC	DC
11.	VIT -D	WELL	5000 L	DC	DC	DC	DC	DC	DC	DC	DC
12.	VIT -D	DRINKING	6000 L	DC	DC	DC	DC	DC	DC	DC	DC
13.	VIT -E	WELL	3000 L	DC	DC	DC	DC	DC	DC	DC	DC
14.	VIT -E	WELL	5000 L	DC	DC	DC	DC	DC	DC	DC	DC
15.	VIT -E	DRINKING	6000 L	DC	DC	DC	DC	DC	DC	DC	DC
16.	VIT -F	WELL	3000 L		1		02		12		20
17.	VIT -F	WELL	5000 L		1		02		12		20
18.	VIT -F	DRINKING	6000 L	28	30	5		27	12	24	
19.	VIT -G	WELL	3000 L		30		03		12		20
20.	VIT -G	WELL	5000 L		30		03		13		20
21.	VIT -G	DRINKING	6000 L	28	1	5		27	13	24	
22.	VP	DRINKING	3000 L	28	1	5		27	13	25	
23.	VP	WELL	5000 L		1		03		13		20
24.	VITPUMP	DRINKING	500 L	28	2	5		27	13	25	
25.	M	FIRE	10000 L	28	2	5		27	13		
26.	M	FIRE	10000 L	28	2	5		27	13		
27.	M	DRINKING	10000 L	27	2	5		27	13		
28.	M	DRINKING	10000 L	27	2	5		27	13	25	
29.	M	WELL	10000 L		2		03		13	25	20
30.	M	WELL	10000 L		2		03		13		20
31.	M PUMP	DRINKING	500 L	28	30	5		27	13	25	

### UNDERGROUND WATER TANKS CLEANING REPORT DATEWISE

1.	VITPUMP	DRINKING	100000 L	27	1	4		26	13		
2.	VITPUMP	FIRE	100000 L	27	1	4		26	12		
3.	M	FIRE	50000 L	27	30	4		27	12		
4.	M	FIRE	50000 L	28	30	5		27	12		
5.	M	DRINKING	50000 L	28	2	5			12		
6.	M	WELL	50000 L		2		03		12		20

DATES- J: JANUARY, M: MARCH, N: NOVEMBER.

**WORK REPORT: TANK CLEANING: 02/11/22**  
**WELL WATER OVERHEAD TANKS**  
**VIDYALANKAR EDUCATIONAL CAMPUS (VDT)**

BLOCK	CAPACITY	TANK NO	TIME	STAGE 1	STAGE 2	STAGE 3	STAGE 4	STAGE 5	STAGE 6	
M	10 K LTR	29	START	15:22	15:25	15:30	15:35	15:42	15:47	
			FINISH	15:55	16:00	16:05	16:10	16:15	16:22	
		30	START		16:10	16:15	16:20	16:25	16:32	16:37
			FINISH		16:25	16:30	16:35	16:40	16:47	16:52
VIT A	3 K LTR	01	START	16:10	16:15	16:20	16:25	16:32	16:37	
			FINISH	16:25	16:30	16:35	16:40	16:47	16:52	
		02	START	16:35	16:40	16:45	16:50	16:57	17:02	
			FINISH	16:50	16:55	17:00	17:05	17:12	17:17	
VIT B	3 K LTR	04	START	11:51	11:55	12:00	12:05	12:12	12:17	
			FINISH	12:06	12:10	12:15	12:20	12:27	12:32	
		05	START	12:20	12:25	12:30	12:35	12:42	12:47	
			FINISH	12:35	12:40	12:45	12:50	12:57	13:02	
VIT C	3 K LTR	07	START	13:35	13:40	13:45	13:50	13:57	14:02	
			FINISH	13:50	13:55	14:00	14:05	14:12	14:17	
		08	START	14:05	14:10	14:15	14:20	14:27	14:32	
			FINISH	14:20	14:25	14:30	14:35	14:42	14:47	
VIT D	3 K LTR	10	START							
			FINISH							
		11	START							
			FINISH							
VIT E	3 K LTR	13	START							
			FINISH							
		14	START							
			FINISH							
VIT F	3 K LTR	16	START	15:12	15:15	15:20	15:25	15:32	15:37	
			FINISH	15:25	15:30	15:35	15:40	15:47	15:52	
		17	START	15:45	15:50	15:55	16:00	16:07	16:12	
			FINISH	16:00	16:05	16:10	16:15	16:22	16:27	
VIT G	3 K LTR	20	START	16:02	16:05	16:10	16:15	16:22	16:27	
			FINISH	16:15	16:20	16:25	16:30	16:37	16:42	
		21	START	17:25	17:30	17:35	17:40	17:47	17:52	
			FINISH	17:40	17:45	17:50	17:55	18:02	18:07	

NOTE: STAGE 1 – De Watering the tanks      STAGE 2 – Hydro blasting water jetting cleaning  
 STAGE 3 – Slurry removal                      STAGE 4 – Anti bacterial treatment  
 STAGE 5 – Vacuum cleaning                      STAGE 6 – Total sterilization with ultra violet tube.

*Dinesh*  
 ( DINESH ) (      )  
 True vision

*P Mishra*  
 ( P MISHRA )  
 Sec Sup

*S S Gode*  
 ( S S GODE )  
 Security Officer

**WORK REPORT: TANK CLEANING: / /202**  
**DRINKING WATER OVERHEAD TANKS**  
**VIDYALANKAR EDUCATIONAL CAMPUS (VDT)**

BLOCK	DATE / CAPACITY L	TANK NO	TIME	STAGE 1	STAGE 2	STAGE 3	STAGE 4	STAGE 5	STAGE 6
M	10 K	25	START						
			FINISH						
		26	START						
			FINISH						
		27	START						
			FINISH						
		28	START						
			FINISH						
PUMP M	1 K	31	START						
			FINISH						
VIT A	5 K	03	START						
			FINISH						
VIT B	5 K	06	START						
			FINISH						
VIT C	6 K	09	START						
			FINISH						
VIT D	6 K	12	START						
			FINISH						
VIT E	6 K	15	START						
			FINISH						
VIT F	6 K	18	START						
			FINISH						
VIT G	6 K	19	START						
			FINISH						
PUMP VIT	0.5 K	24	START						
			FINISH						
VP	3 K	22	START						
			FINISH						
		23	START						
			FINISH						
<b>UNDERGROUND TANKS DRINKING / WELL</b>									
VIT	3 K	01 DRINKING	START						
			FINISH						
		02 FIRE	START						
			FINISH						
M	3 K	03 FIRE	START						
			FINISH						
		04 FIRE	START						
			FINISH						

M	3 K	05 DRINKING	START						
			FINISH						
		06 WELL	START	14:20	14:25	14:30	14:35	14:40	14:45
			FINISH	14:45	14:50	14:55	15:00	15:05	15:10

NOTE: STAGE 1 – De Watering the tanks  
 STAGE 2 – Hydro blasting water jetting cleaning  
 STAGE 3 – Slurry removal  
 STAGE 4 – Anti bacterial treatment  
 STAGE 5 – Vacuum cleaning  
 STAGE 6 – Total sterilization with ultra violet tube.

*(Signature)*  
 ( DINESH )  
 True vision

*(Signature)*  
 ( P MISHRA )  
 Sec Sup

*(Signature)*  
 ( S S GODE )  
 Security Officer

Vidyalankar Dnyanapeeth Trust's  
Vidyalankar Institute of Technology  
Wadala (E), Vidyalankar College Marg, Mumbai-400037  
+91 22 2416 11 26  
vidyalankar.edu.in  
GST No.: AAATV2195F1ZC

**VIT** Vidyalankar  
Institute of  
Technology  
Accredited A+ by NAAC

To,

TRUE VISION SERVICES

3 ALPS HIGHTS 1 ST FLOOR DR.R.P.ROAD MULUND(W) MUM-80 MUMBAI - 400080

022-65234565 /

Contact Person :----

PO Number : 04800

PO Date : 10-03-2022

Please arrange to supply following to Vidyalankar Institute of Technology.

Furnish Delivery Challan and Cash Memo / Invoice along with delivered goods.

Sr. No.	Item Name	Item Remarks	Quantity	Unit Rate (₹)	Total Amount (₹)	Add Taxes (GST)
1	SERVICE CONTRACT	THE TANK CLEAN SERVICE CONTRACT ( ASC-3 ) FROM 01.04.2022 TO 31.03.2023 .... VIT	1(Number)	40000.00	40000.00	0.00
2	SERVICE CONTRACT	THE TANK CLEAN SERVICE CONTRACT ( ASC-3 ) FROM 01.04.2022 TO 31.03.2023 .... M BLOCK	1(Number)	30000.00	30000.00	0.00
Total Amount :					70000.00#	# + Taxes as Above
Round Off Amount :					₹ 70000.00	

Amount in Words :Seventy Thousand rupees only

PO Remarks :1) AMC PERIOD : 01.04.2022 TO 31.03.2023

2) TAXES : ALL INCLUSIVE


3) DOMESTIC : 3 TIMES IN A YEAR

4) FLUSH : 2 TIMES IN A YEAR

5) PAYMENT TERMS : 50% WITH PO & 50% AFTER 6 MONTHS

AMOUNT WILL BE PAID AS PER PURCHASE ORDER OR AT ACTUALS, WHICHEVER IS LESS.

Principal

  
For Vidyalankar Institute of Technology (VIT)

## VIDYALANKAR EDUCATIONAL CAMPUS 2021-2022

### OVERHEAD WATER TANKS CLEANING REPORT DATEWISE

TANK NO	BLDG/ BLOK	WATER TYPE	CAP	2021				2022			
				FEB	JUN	OCT	DEC	FEB	JUN	OCT	DEC
1.	VIT -A	WELL	3000 L		30		02		12		
2.	VIT -A	WELL	5000 L		30		02		12		
3.	VIT -A	DRINKING	6000 L	27	1	4		26	12	24	
4.	VIT -B	WELL	3000 L		1		02		12		
5.	VIT -B	WELL	5000 L		1		02		12		
6.	VIT -B	DRINKING	6000 L	27	1	4		26	12	24	
7.	VIT -C	WELL	3000 L		1		02		12		
8.	VIT -C	WELL	5000 L		2		02		12		
9.	VIT -C	DRINKING	6000 L	27	2	4		26	12	26	
10.	VIT -D	WELL	3000 L	DC	DC				DE		
11.	VIT -D	WELL	5000 L	DC	DC				DE		
12.	VIT -D	DRINKING	6000 L	DC	DC				DE		
13.	VIT -E	WELL	3000 L	DC	DC				DE		
14.	VIT -E	WELL	5000 L	DC	DC				DE		
15.	VIT -E	DRINKING	6000 L	DC	DC			DE	DE		
16.	VIT -F	WELL	3000 L		1		02		12		
17.	VIT -F	WELL	5000 L		1		02		12		
18.	VIT -F	DRINKING	6000 L	28	30	5		27	12	24	
19.	VIT -G	WELL	3000 L		30		03		12		
20.	VIT -G	WELL	5000 L		30		03		13		
21.	VIT -G	DRINKING	6000 L	28	1	5		27	13	24	
22.	VP	DRINKING	3000 L	28	1	5		27	13	25	
23.	VP	WELL	5000 L		1		03		13		
24.	VITPUMP	DRINKING	500 L	28	2	5		27	13	25	
25.	M	FIRE	10000 L	28	2	5		27	13		
26.	M	FIRE	10000 L	28	2	5		27	13		
27.	M	DRINKING	10000 L	27	2	5		27	13	25	
28.	M	DRINKING	10000 L	27	2	5		27	13	25	
29.	M	WELL	10000 L		2		03		13		
30.	M	WELL	10000 L		2		03		13		
31.	M PUMP	DRINKING	500 L	28	30	5		27	13	25	

### UNDERGROUND WATER TANKS CLEANING REPORT DATEWISE

1.	VITPUMP	DRINKING	100000 L	27	1	4		26	13	25	
2.	VITPUMP	FIRE	100000 L	27	1	4		26	12	25	
3.	M	FIRE	50000 L	27	30	4		27	12	25	
4.	M	FIRE	50000 L	28	30	5		27	12	25	
5.	M	DRINKING	50000 L	28	2	5			12	25	
6.	M	WELL	50000 L		2		03		13		

DATES- J: JANUARY, M: MARCH, N: NOVEMBER.

  
Security Officer

WORK REPORT: TANK CLEANING:

04-05 / MON / 2022

DRINKING WATER OVERHEAD TANKS  
VIDYALANKAR EDUCATIONAL CAMPUS (VDT)

BLOCK / CAPACITY	DATE	TANK NO	TIME	STAGE 1	STAGE 2	STAGE 3	STAGE 4	STAGE 5	STAGE 6		
M 10 K		25	START	9:50	10:01	10:00	10:10	10:18	10:16		
			FINISH	9:59	10:13	10:05	10:12	10:15	10:26		
		26	START	5	10:27	10:35	10:35	10:38	10:41		
			FINISH	5	10:30	10:33	10:37	10:40	10:51		
		27	START	10:53	11:36	11:40	11:43	11:46	11:49		
			FINISH	11:35	11:39	11:42	11:45	11:48	12:09		
		28	START	9	12:00	12:03	12:06	12:10	12:13		
			FINISH	9	12:02	12:05	12:08	12:12	12:23		
		PUMP M 1 K		31	START	7:12	7:18	7:18	7:21	7:24	7:28
					FINISH	7:14	7:17	7:20	7:23	7:26	7:38
		VIT A 6 K		03	START	12:02	12:06	12:10	12:16	12:17	12:20
					FINISH	12:04	12:08	12:13	12:16	12:19	12:30
VIT B 6 K		06	START	12:35	12:42	12:46	12:50	12:54	13:00		
			FINISH	12:40	12:45	12:49	12:53	12:56	13:10		
VIT C 6 K		09	START	14:15	14:20	14:23	14:27	14:31	14:35		
			FINISH	14:19	14:22	14:25	14:30	14:34	14:45		
VIT D 6 K		12	START								
			FINISH								
VIT E 6 K		15	START								
			FINISH								
VIT F 6 K		18	START	14:55	15:01	15:05	15:10	15:15	15:20		
			FINISH	14:57	15:04	15:07	15:12	15:17	15:30		
VIT G 6 K		19	START	15:40	15:45	15:51	15:54	15:59	16:03		
			FINISH	15:44	15:50	15:53	15:57	16:02	16:16		
PUMP VIT 0.5 K		24	START	13:43	13:47	13:50	13:53	13:56	14:07		
			FINISH	13:46	13:49	13:52	13:55	13:59	14:10		
VP 3 K		22	START	16:50	16:56	17:00	17:04	17:08	17:11		
			FINISH	16:55	16:57	17:00	17:03	17:10	17:21		
		23	START								
			FINISH								

UNDERGROUND TANKS DRINKING / WELL

VIT 3 K	DRINKING	01	START	10:10	10:14	10:15	10:16	10:55	11:03
			FINISH	10:30	10:35	10:40	10:53	11:02	11:05
		02	START	11:03	12:17	12:53	12:02	13:12	13:17
			FINISH	12:45	12:31	12:57	13:10	12:16	13:40
M		03	START	15:52	15:37	12:40	12:51	16:02	16:09

3 K	FIRE	FINISH	17:35	17:42	17:50	18:00	18:08	18:12
		04	START		18:20	18:30	18:37	18:52
		FIRE	FINISH	5	18:34	18:38	18:45	19:10
M 3 K	DRINKING	05	START	14:30	14:32	15:05	15:12	15:28
		FINISH	14:50	14:55	15:12	15:20	15:40	
	06 WELL	START						
		FINISH						

NOTE: STAGE 1 – De Watering the tanks  
 STAGE 2 – Hydro blasting water jetting cleaning  
 STAGE 3 – Slurry removal  
 STAGE 4 – Anti bacterial treatment  
 STAGE 5 – Vacuum cleaning  
 STAGE 6 – Total sterilization with ultra violet tube.

( DINESH ) ( )  
 True vision

( MANOJ BANSODE )  
 Sec Sup

( S S GODE )  
 Security Officer



4

**VIDYALANKAR EDUCATIONAL CAMPUS 2021-2022**

**OVERHEAD WATER TANKS CLEANING REPORT DATEWISE**

TANK NO	BLDG/ BLOK	WATER TYPE	CAP	2021				2022			
				FEB	JUN	OCT	DEC	FEB	JUN	OCT	DEC
1.	VIT -A	WELL	3000 L		30		02		12		
2.	VIT -A	WELL	5000 L		30		02		12		
3.	VIT -A	DRINKING	6000 L	27	1	4		26	12	24	
4.	VIT -B	WELL	3000 L		1		02		12		
5.	VIT -B	WELL	5000 L		1		02		12		
6.	VIT -B	DRINKING	6000 L	27	1	4		26	12	24	
7.	VIT -C	WELL	3000 L		1		02		12		
8.	VIT -C	WELL	5000 L		2		02		12		
9.	VIT -C	DRINKING	6000 L	27	2	4		26	12	24	
10.	VIT -D	WELL	3000 L	DC	DC				DE		
11.	VIT -D	WELL	5000 L	DC	DC				DE		
12.	VIT -D	DRINKING	6000 L	DC	DC				DE		
13.	VIT -E	WELL	3000 L	DC	DC				DE		
14.	VIT -E	WELL	5000 L	DC	DC				DE		
15.	VIT -E	DRINKING	6000 L	DC	DC			DE	DE		
16.	VIT -F	WELL	3000 L		1		02		DE	DE	
17.	VIT -F	WELL	5000 L		1		02		12		
18.	VIT -F	DRINKING	6000 L	28	30	5		27	12	24	
19.	VIT -G	WELL	3000 L		30		03		12		
20.	VIT -G	WELL	5000 L		30		03		13		
21.	VIT -G	DRINKING	6000 L	28	1	5		27	13	24	
22.	VP	DRINKING	3000 L	28	1	5		27	13	25	
23.	VP	WELL	5000 L		1		03		13		
24.	VITPUMP	DRINKING	500 L	28	2	5		27	13	25	
25.	M	FIRE	10000 L	28	2	5		27	13		
26.	M	FIRE	10000 L	28	2	5		27	13		
27.	M	DRINKING	10000 L	27	2	5		27	13	25	
28.	M	DRINKING	10000 L	27	2	5		27	13	25	
29.	M	WELL	10000 L		2		03		13		
30.	M	WELL	10000 L		2		03		13		
31.	M PUMP	DRINKING	500 L	28	30	5		27	13	25	

**UNDERGROUND WATER TANKS CLEANING REPORT DATEWISE**

1.	VITPUMP	DRINKING	100000 L	27	1	4		26	13	25	
2.	VITPUMP	FIRE	100000 L	27	1	4		26	12	25	
3.	M	FIRE	50000 L	27	30	4		27	12	25	
4.	M	FIRE	50000 L	28	30	5		27	12	25	
5.	M	DRINKING	50000 L	28	2	5			12	25	
6.	M	WELL	50000 L		2		03		13		

DATES- J: JANUARY, M: MARCH, N: NOVEMBER.

*[Signature]*  
Security Officer

WORK REPORT: TANK CLEANING: 12 July 2022

DRINKING WATER OVERHEAD TANKS

VIDYALANKAR EDUCATIONAL CAMPUS (VDT)

BLOCK	DATE / CAPACITY L	TANK NO	TIME	STAGE 1	STAGE 2	STAGE 3	STAGE 4	STAGE 5	STAGE 6
M	10 K	25	START	9:35	9:52	9:58	10:06	10:12	10:18
		FINISH	9:50	9:55	9:56	10:00	10:06	10:12	
		26	START	10:30	10:37	10:42	10:47	10:52	10:59
		FINISH	10:35	10:40	10:45	10:50	10:55	11:00	
		27	START	11:12	11:27	11:42	11:47	11:52	11:58
		FINISH	11:35	11:40	11:46	11:50	11:55	12:02	
PUMP M	1 K	28	START		12:17	12:19	12:24	12:29	12:35
		FINISH		12:18	12:23	12:28	12:33	12:38	
VIT A	6 K	31	START	7:53	7:56	7:59	8:05	8:09	8:13
		FINISH	7:55	7:58	8:04	8:08	8:12	8:20	
VIT B	6 K	03	START	9:20	9:30	9:35	9:39	9:43	9:53
		FINISH	9:26	9:33	9:38	9:42	9:46	9:57	
VIT C	6 K	06	START	11:12	11:16	11:19	11:23	11:28	11:31
		FINISH	11:18	11:18	11:22	11:25	11:30	11:37	
VIT D	6 K	09	START	11:01	11:03	11:12	11:16	11:19	11:23
		FINISH	11:05	11:11	11:14	11:18	11:22	11:33	
VIT E	6 K	12	START						
		FINISH							
VIT F	6 K	15	START						
		FINISH							
VIT G	6 K	18	START	2:42	2:46	2:50	2:53	2:56	3:00
		FINISH	2:45	2:49	2:52	2:55	2:58	3:10	
PUMP VIT VP	0.5 K	19	START	4:22	4:26	4:33	4:33	4:36	4:40
		FINISH	4:25	4:29	4:32	4:35	4:39	4:50	
PUMP VIT VP	3 K	24	START	6:16	6:20	6:23	6:26	6:29	6:33
		FINISH	6:19	6:22	6:25	6:28	6:32	6:45	
PUMP VIT VP	3 K	22	START	3:50	3:55	4:13	4:24	4:26	4:29
		FINISH	3:50	3:50	4:22	4:29	4:28	4:34	
PUMP VIT VP	3 K	23	START	5:00	5:12	5:22	5:26	5:32	5:37
		FINISH	5:10	5:20	5:24	5:30	5:36	5:47	

UNDERGROUND TANKS DRINKING / WELL

VIT	3 K	01	START	8:35	8:42	8:44	8:46	8:51	8:52
		DRINKING	FINISH	8:40	8:48	8:50	8:50	8:56	9:06
M	3 K	02	START	10:15	10:52	12:46	12:52	1:03	1:12
		FIRE	FINISH	12:30	12:45	12:51	1:01	1:12	1:31
M	3 K	03	START	4:48	6:31	6:36	6:41	6:52	6:59
		FIRE	FINISH	6:30	6:35	6:40	6:50	6:58	7:15
M	3 K	04	START		7:16	7:22	7:31	7:36	7:41
		FIRE	FINISH		7:20	7:30	7:35	7:40	7:51

WORK REPORT: TANK CLEANING: / /202  
WELL WATER OVERHEAD TANKS

VIDYALANKAR EDUCATIONAL CAMPUS (VDT)

BLOCK	CAPACITY	TANK NO	TIME	STAGE	STAGE	STAGE	STAGE	STAGE	STAGE
				1	2	3	4	5	6
M	10 KLTR	29	START	11:22	11:32	21:00	21:06	21:12	21:17
			FINISH	11:55	11:59	21:04	21:10	21:15	21:27
		30	START	5	21:30	21:36	21:42	21:48	21:50
			FINISH		21:35	21:40	21:45	21:52	21:55
VIT A	3 KLTR	31	START	10:01	10:07	10:11	10:12	10:20	10:22
			FINISH	10:05	10:09	10:14	10:18	10:21	10:32
		32	START	10:33	10:41	10:45	10:48	10:52	10:54
			FINISH	10:40	10:43	10:47	10:51	10:53	10:54
VIT B	3 KLTR	34	START	11:59	11:58	12:03	12:06	12:10	12:13
			FINISH	11:56	12:00	12:05	12:08	12:12	12:23
		05	START	12:26	2:31	12:34	12:38	12:41	12:45
			FINISH	12:30	2:33	12:37	12:40	12:44	12:55
VIT C	3 KLTR	07	START	1:35	1:38	1:41	1:46	1:48	1:51
			FINISH	1:37	1:40	1:43	1:46	1:50	2:00
		08	START	2:01	2:05	2:04	2:12	2:16	2:22
			FINISH	2:04	2:08	2:11	2:15	2:14	2:32
VIT D	3 KLTR	10	START						
			FINISH						
		11	START						
			FINISH						
VIT E	3 KLTR	13	START						
			FINISH						
		14	START						
			FINISH						
VIT F	3 KLTR	16	START	3:12	3:16	3:20	3:24	3:28	3:31
			FINISH	3:15	3:19	3:22	3:24	3:30	3:41
		17	START	3:42	3:45	3:48	3:51	3:56	4:01
			FINISH	3:45	3:47	3:50	3:53	4:00	4:10
VIT G	3 KLTR	20	START	4:52	4:55	4:59	5:04	5:08	5:10
			FINISH	4:57	4:58	5:02	5:07	5:10	5:12
		21	START	5:20	5:30	5:34	5:38	5:42	5:45
			FINISH	5:24	5:32	5:36	5:40	5:44	5:53

Z

NOTE: STAGE 1 - De Watering the tanks  
STAGE 3 - Slurry removal  
STAGE 5 - Vacuum cleaning

STAGE 2 - Hydro blasting water jetting cleaning  
STAGE 4 - Anti bacterial treatment  
STAGE 6 - Total sterilization with ultra violet tube.

*[Signature]*  
True Vision

*[Signature]*  
(Sum) Kambley  
Sec Sup

*[Signature]*  
Security Officer

M	3 K	05	START	2:40	3	52	2:01	2:11	4:18	4:26
		DRINKING	FINISH	3:50	3	59	4:11	4:16	4:25	4:30
		06	START	2:30	2	40	2:53	2:05	3:13	3:18
		WELL	FINISH	2:45	3	52	3:10	3:12	3:18	3:20

- NOTE: STAGE 1 – De Watering the tanks  
 STAGE 2 – Hydro blasting water jetting cleaning  
 STAGE 3 – Slurry removal  
 STAGE 4 – Anti bacteria! treatment  
 STAGE 5 – Vacuum cleaning  
 STAGE 6 – Total sterilization with ultra violet tube.

(*[Signature]*)  
 True vision )

(*[Signature]*)  
 (Rajy Chaita)  
 Sec Sup

(*[Signature]*)  
 SS) hoda  
 Security Officer

WORK REPORT: TANK CLEANING: / /202

WELL WATER OVERHEAD TANKS

VIDYALANKAR EDUCATIONAL CAMPUS (VDT)

BLOCK	CAPACITY	TANK NO	TIME	STAGE 1	STAGE 2	STAGE 3	STAGE 4	STAGE 5	STAGE 6
M	10 K LTR	29	START						
			FINISH						
		30	START						
			FINISH						
VIT A	3 K LTR	01	START						
			FINISH						
		02	START						
			FINISH						
VIT B	3 K LTR	04	START						
			FINISH						
		05	START						
			FINISH						
VIT C	3 K LTR	07	START						
			FINISH						
		08	START						
			FINISH						
VIT D	3 K LTR	10	START						
			FINISH						
		11	START						
			FINISH						
VIT E	3 K LTR	13	START						
			FINISH						
		14	START						
			FINISH						
VIT F	3 K LTR	16	START						
			FINISH						
		17	START						
			FINISH						
VIT G	3 K LTR	20	START						
			FINISH						
		21	START						
			FINISH						

NOTE: STAGE 1 – De Watering the tanks  
 STAGE 3 – Slurry removal  
 STAGE 5 – Vacuum cleaning

STAGE 2 – Hydro blasting water jetting cleaning  
 STAGE 4 – Anti bacterial treatment  
 STAGE 6 – Total sterilization with ultra violet tube.

( )  
 True vision

( )  
 Sec Sup

( )  
 Security Officer

TANK CLEANING REPORT: 23/02/2022 208 29/02/2022  
 DRINKING WATER OVERHEAD TANKS  
 VIDYALANKAR EDUCATIONAL CAMPUS (VDT)

BLOCK	DATE / CAPACITY L	TANK NO	TIME	STAGE 1	STAGE 2	STAGE 3	STAGE 4	STAGE 5	STAGE 6
M	10 K	25	START	9:50	9:00	10:05	10:10	10:13	10:18
			FINISH	9:59	10:03	10:08	10:12	10:15	10:26
		26	START	9:59	10:27	10:31	10:35	10:38	10:41
			FINISH	9:59	10:30	10:33	10:37	10:40	10:51
		27	START	10:53	11:26	11:40	11:43	11:46	11:49
			FINISH	11:35	11:39	11:42	11:45	11:48	11:59
28	START	12:00	12:00	12:03	12:06	12:10	12:13		
	FINISH	12:02	12:05	12:08	12:12	12:23			
PUMP M	1 K	31	START	7:12	7:15	7:16	7:21	7:22	7:28
			FINISH	7:14	7:17	7:20	7:23	7:26	7:38
VIT A	6 K	03	START	1:02	1:06	1:10	1:14	1:19	1:20
			FINISH	1:04	1:08	1:13	1:16	1:19	1:30
VIT B	6 K	06	START	1:35	1:42	1:46	1:50	1:53	2:00
			FINISH	1:40	1:45	1:49	1:53	1:56	2:10
VIT C	6 K	09	START	2:15	2:20	2:23	2:27	2:31	2:35
			FINISH	2:19	2:22	2:25	2:30	2:34	2:45
VIT D	6 K	12	START						
			FINISH						
VIT E	6 K	15	START						
			FINISH						
VIT F	6 K	18	START	2:55	3:01	3:05	3:10	3:15	3:20
			FINISH	2:59	3:04	3:08	3:12	3:18	3:30
VIT G	6 K	19	START	3:40	3:45	3:51	3:54	3:59	4:03
			FINISH	2:44	3:50	3:53	3:58	4:02	4:14
PUMP VIT	0.5 K	24	START	1:43	1:47	1:50	1:53	1:56	2:00
			FINISH	1:46	1:49	1:52	1:55	1:59	2:10
VP	3 K	22	START	4:50	4:56	5:00	5:04	5:08	5:11
			FINISH	4:55	4:59	5:03	5:07	5:10	5:21
	23	START							
		FINISH							

UNDERGROUND TANKS DRINKING / WELL

VIT	3 K	01 DRINKING	START	10:10	10:31	10:36	10:46	10:55	11:03
			FINISH	10:30	10:35	10:45	10:53	11:02	11:25
		02 FIRE	START	11:23	12:42	12:53	1:02	1:12	1:17
			FINISH	12:45	1:51	12:59	1:10	1:16	1:40
M	3 K	03 FIRE	START	3:52	5:37	5:44	5:51	6:02	6:09
			FINISH	5:35	5:42	5:50	5:59	6:08	6:25
		04 FIRE	START	5:25	6:23	6:33	6:39	6:47	6:52
			FINISH	6:52	6:56	6:45	6:51	7:10	
M	3 K	05 DRINKING	START	2:30	2:52	3:05	3:13	3:21	3:28
			FINISH	2:50	2:59	3:12	3:20	3:25	3:48

2/02

2/02

2/02

M		05	START	
	3 K	DRINKING	FINISH	
		06	START	
		WELL	FINISH	

NOTE: STAGE 1 – De Watering the tanks  
 STAGE 2 – Hydro blasting water jetting cleaning  
 STAGE 3 – Slurry removal  
 STAGE 4 – Anti bacterial treatment  
 STAGE 5 – Vacuum cleaning  
 STAGE 6 – Total sterilization with ultra violet tube.

( २३/०५/२०१८ ) ( ११/०५/१८ )  
 True vision

२१/०५/१८  
 (Rajiv Chokhan)  
 Sec Sup

  
 (S.S. Gode)  
 Security Officer

Security Officer

Shriyankar Dnyanapeeth Trust's  
 VIDYALANKAR EDUCATIONAL CAMPUS  
 Wadgaon (B), Mumbai-400 037. Tel.: 9122 2416 1120